

TAMIL NADU FIRE & RESCUE SERVICES
FIRE LICENCE

Under Section 13 of the Tamil Nadu Fire Service Act No.40 of 1985 and with Tamil Nadu fire Service Rules 1990-Appendix-III

Licence No. ¹⁵⁶⁸/2022
R.C.No. 12703/A/ 2022

Date : 30.12.2022

Licence is hereby granted under section 13 of the Tamil Nadu Fire Service Act 1985 for To Run Educational Institute (Mention Whichever is applicable) within the Jurisdiction of OMR Municipality in the Name of Company M/S. SATHYABAMA INSTITUTE OF SCIENCE & TECHNOLOGY, Jeppiar Nagar, Rajiv Gandhi Salai, OMR, Thiruporur Taluk, Chengalpattu District. subject to the conditions noted thereon and such other conditions as may be prescribed. Inspected by **ASSISTANT DISTRICT OFFICER CHENGALPATTU** on 24.12.2022 and this Licence is Valid upto 23.12.2023.

CONDITIONS

1. As per National Building code of india 2016, Part – IV Fire and Life Safety, Periodical maintenance and care should be taken to all fire protection equipments with good working condition at all times and a register should be maintained.
2. The First aid fire fighting equipments should be maintained at all floors in accordance with the ISO 2190:2010 requirements.
3. Staffs should be trained in preliminary fire fighting as per G.O.NO:713 Home (Police-17), Dated:17.08.2005 with Fire and Rescue Services Department.
4. Fire drill should be conducted at least once in every six months with the local Fire and Rescue Service authorities and a permanent register should be maintained in part-1
5. This Licence is valid for one year from the date of issue.
6. The applicant will also get permission/No objection certificate from other department if necessary.
7. Regular Licence has to be obtained from competent authority.
8. If there is any deviation from the govt.Rule and Act the licence issued will stand cancelled.
9. All the Fire Extinguishers have to be recharged and maintained periodically as per code practice in ISO 2190/2010
10. Advise to train the employee to operate the fire Extinguisher.

(Office Seal)



1.1.2023
District Officer,
Fire and Rescue Services,
Chengalpattu.

TO:
M/S. SATHYABAMA INSTITUTE OF SCIENCE & TECHNOLOGY,
Jeppiar Nagar, Rajiv Gandhi Salai, OMR,
Thiruporur Taluk, Chengalpattu District.

Copy to: The Dy. Director, North-Western Region. T.N.F.R.S. Vellore.