

CONDITIONAL MONITORING AND MEASUREMENT OF VIBRATION

Submitted in partial fulfillment of the requirements for the award of

Bachelor of Engineering degree in
Mechanical Engineering

By

ROSHAN JEROLD R (Reg. No. 40150040)

KAMESH V (Reg. No. 40150710)



DEPARTMENT OF MECHANICAL ENGINEERING

SCHOOL OF MECHANICAL ENGINEERING

SATHYABAMA

INSTITUTE OF SCIENCE AND TECHNOLOGY

(DEEMED TO BE UNIVERSITY)

Accredited with grade "A++" by NAAC

JEPPIAAR NAGAR, RAJIV GANDHI SALAI, CHENNAI – 600119

APRIL - 2024



SATHYABAMA

INSTITUTE OF SCIENCE AND TECHNOLOGY
(DEEMED TO BE UNIVERSITY)

Accredited "A++" Grade by NAAC | 12B Status by UGC | Approved by AICTE
www.sathyabama.ac.in

DEPARTMENT OF MECHANICAL ENGINEERING

BONAFIDE CERTIFICATE

This is to certify that this Project Report is the bonafide work of ROSHAN JEROLD R (Reg. No. 40150040) and KAMESH V (Reg. No. 40150710) who carried out the project entitled "CONDITIONAL MONITORING AND MEASUREMENT OF VIBRATION" under our supervision from December 2023 to April 2024.

Internal Guide

Dr. V. SIVAPRAKASH, M.E., Ph.D.,

Head of the Department

Dr. S. GANESAN., M.E., Ph.D.,

Submitted for Viva voce Examination held on 6/04/2024

Internal Examiner

External Examiner

DECLARATION

We ROSHAN JEROLD R (Reg. No. 40150040) and KAMESH V (Reg. No. 40150710) hereby declare that the Project Report entitled "CONDITIONAL MONITORING AND MEASUREMENT OF VIBRATION" done by me under the guidance of Dr. V. SIVAPRAKASH., M.E., Ph.D. is submitted in partial fulfilment of the requirements for the award of Bachelor of Engineering degree in Mechanical Engineering.

1. J. Roshan Jerold

2. V. Kamesh

DATE: 6/04/2024

PLACE: CHENNAI

SIGNATURE OF THE CANDIDATES

ACKNOWLEDGEMENT

I am pleased to acknowledge my sincere thanks to Board of Management of **SATHYABAMA** for their kind encouragement in doing this project and for completing it successfully. I am grateful to them.

I convey my sincere thanks to **Dr. S. GANESAN., M.E., Ph.D.**, Head of the Department, Department of Mechanical Engineering for providing me necessary support and details at the right time during the progressive reviews.

I would like to express my sincere and deep sense of gratitude to my Project Guide **Dr. V. SIVAPRAKASH., M.E., Ph.D.**, for his valuable guidance, suggestions, and constant encouragement paved way for the successful completion of my project work.

I also express my thanks to all Teaching and Non-teaching staff members of the Department of Mechanical Engineering who were helpful in many ways for the completion of the project.

ABSTRACT

In several industries, including wearable technology, machinery diagnostics, and structural health monitoring, vibration monitoring is essential. This study provides a thorough analysis and practical application of a vibration monitoring system that makes use of the MPU-6050 sensor. The MPU-6050 is a small device that combines a three-axis accelerometer and gyroscope to provide accurate motion tracking. The design and implementation of the proposed system are described, including information on the data gathering procedure, signal processing methods, and sensor configuration. Diverse vibration analysis techniques, such as time-domain and frequency-domain methods, are examined, offering valuable perspectives on deriving significant information from unprocessed sensor data. The study also discusses calibration methods to improve the monitoring system's accuracy and dependability. To ensure the accuracy of vibration measurements, calibration methods for reducing sensor errors—such as bias, scale factor, and cross-axis sensitivity—are explained. installing the MPU6050 sensor to record vibration data while the solenoid vibration generator is in use. Utilizing signal processing methodologies, we scrutinize the unprocessed data acquired from the sensor and derive significant discernments concerning the vibration attributes. In addition, we create a software interface to view and analyze the vibration patterns that are being tracked in real time.

TABLE OF CONTENTS

CHAPTER NO.	TITLE	Page NO.
	ABSTRACT	v
	LIST OF FIGURES	viii
	LIST OF TABLES	xi
1	INTRODUCTION	1
	1.1 Basics of vibration	1
	1.2 History of vibration analysis techniques	2
	1.3 Types of vibration analysis techniques	3
	1.3.1 Time-Domain Analysis	4
	1.3.2 Frequency -Domain analysis	5
	1.3.3 Amplitude modulation analysis	7
	1.3.4 Phase analysis	8
	1.3.5 Order analysis	9
	1.3.6 Resonance Detection	10
	1.3.7 Gear and bearing fault detection	10
	1.3.8 Tracking changes over time	10
	1.3.9 Diagnostic clarity	11
	1.4 Modular analysis	12
	1.4.1 Natural frequencies	12
	1.4.2 Mode shapes	12
	1.4.3 Mass, stiffness, and damping matrices	13
	1.4.4 Excitation	14
	1.4.5 Damping ratio	14
	1.4.6 Applications	15
2	LITERATURE SURVEY	16

3	AIM & SCOPE	22
4	MATERIALS AND EXPERIMENTAL METHOD	24
	4.1 Materials	24
	4.2 Vibration Analyzer	24
	4.1.1.2 MEMS Accelerometer	25
	4.1.1.2 Microcontroller	26
	4.1.2 Artificial Vibration generator	28
	4.1.2.1 Selenide actuator	29
	4.1.2.2 Amplifier Pam8610	30
	4.1.2.3 Power Supply	31
	4.1.2.4 Frequency Generator	32
	4.1.3 Data Acquisition System	33
	4.1.4 Cables and Connectors	34
	4.2 Methodology	35
	4.2.1 Vibration Measurement Device	35
	4.2.2 solenoid Vibration Generator Device	36
5	RESULTS AND DISCUSSION	40
	5.1 Results and Discussion	40
6	SUMMARY AND CONCLUSION	42
	6.1 Summary	42
	6.2 Conclusion	42
	REFERENCES	44
	APPENDIX	48

LIST OF FIGURES

FIGURE NO.	TITLE	PAGE NO.
1.1	Vibration detection	2
1.2	Time vs acceleration	5
1.3	Frequency modes	6
1.4	Amplitude vs time	8
4.1	schematic diagram of Mems Accelerometer	26
4.2	Microcontroller Arduino UNO	27
4.3	6V Solenoid Actuator	30
4.4	PAM8610 Amplifier	31
4.5	AC to DC power converter	32
4.6	Sign of Frequency Generator	33
4.7	MPU6050 Vibration Analyser	36
4.8	Image of solenoid Damper	37
4.9	Prototype of Vibration Detector	39
5.1	Graph of vibration level	40
5.2	Setup of vibration detection	41

LIST OF TABLES

TABLE NO.	TITLE	PAGE NO.
4.1	Vibration	22

CHAPTER 1

INTRODUCTION

1.1 BASICS OF VIBRATION

Vibration analysis is a crucial discipline in engineering and predictive maintenance that focuses on the study of mechanical oscillations and their impact on machinery and structures. These oscillations, or vibrations, can manifest in various forms, from simple harmonic motion to complex and irregular patterns. In order to comprehend and interpret these vibrations and gain important insights on the functionality and state of health of mechanical systems, vibration analysis techniques are used. Vibration analysis's main objective is to identify, assess, and keep track of the state of structures and machinery. By examining the frequency, amplitude, and phase of vibrations, analysts can identify potential issues such as imbalances, misalignments, wear and tear, structural weaknesses, and even impending failures. This proactive approach to maintenance is cost-effective and minimizes unplanned downtime, enhancing both safety and operational efficiency in various industries, including manufacturing, aerospace, automotive, and civil engineering.

Vibration analysis employs a range of tools and methods, including accelerometers and vibration sensors to collect data, followed by signal processing techniques to analyze and interpret the data. Common analysis methods include time domain analysis, frequency domain analysis, and time-frequency domain analysis. Time domain analysis involves observing the vibrations in the time domain, while frequency domain analysis decomposes the signal into its constituent frequencies, making it possible to identify dominant vibration sources. Timefrequency domain analysis combines elements of both methods, offering a comprehensive understanding of vibration behavior. Furthermore, vibration analysis can be applied to various types of machinery, from small components like bearings and gears to large rotating equipment and entire industrial plants. With advancements in technology, such as condition monitoring systems and predictive maintenance software, vibration analysis has become more accessible and efficient,

enabling organizations to maintain their assets in an optimal condition and prevent costly breakdowns. Overall, vibration analysis techniques play a vital role in ensuring the reliability and longevity of machinery and structures in today's industrial and engineering landscapes.

1.2 HISTORY OF VIBRATION ANALYSIS TECHNIQUES

The history of vibration analysis techniques is a story of continuous development and evolution, spanning centuries and driven by diverse applications ranging from musical instruments to industrial machinery, structural engineering, and even modern predictive maintenance practices. Vibration analysis can be traced back to ancient civilizations where the study of vibrations was primarily associated with musical instruments and their harmonious sounds. However, the systematic exploration of vibrations began to take shape during the Renaissance period, with notable figures like Galileo Galilei and Leonardo da Vinci making early observations and contributions. Galileo, in the late 16th century, experimented with pendulum oscillations, laying the foundation for understanding periodic vibrations.



Fig:1.1: vibration detection

The Industrial Revolution of the 18th and 19th centuries brought a surge in mechanical engineering and machinery, necessitating more sophisticated tools for analyzing vibrations in industrial equipment. Engineers began developing instruments such as stroboscopes and resonant tuning forks for diagnosing and

addressing mechanical issues in large industrial machines. The early 20th century marked a significant turning point in vibration analysis with the advent of electrical and electronic technology. The invention of the seismograph by John Milne in the late 19th century, originally designed to measure earthquakes, was adapted for monitoring vibrations in industrial equipment. The development of accelerometers, which measure acceleration and convert it into electrical signals, greatly enhanced the precision and versatility of vibration analysis tools. During the mid-20th century, the field of vibration analysis advanced further with the integration of computers and signal processing techniques. The emergence of digital signal processing allowed for more detailed and comprehensive analysis of vibration data. Engineers and researchers could now identify subtle patterns and anomalies in vibration data, enabling predictive maintenance and the prevention of catastrophic machinery failures. Today, vibration analysis has evolved into a highly sophisticated field, with a wide range of techniques and equipment designed to monitor and assess vibrations in various applications. These techniques include spectral analysis, frequency domain analysis, time-domain analysis, and modal analysis, among others. Vibration analysis plays a crucial role in fields such as aerospace, automotive, manufacturing, and structural engineering, where it is used for quality control, structural health monitoring, and predictive maintenance to ensure the safe and efficient operation of complex systems. In summary, the history of vibration analysis techniques reflects a gradual progression from early observations and simple instruments to the high-tech, data-driven methodologies used today. As technology continues to advance, the field of vibration analysis remains at the forefront of ensuring the reliability and performance of machinery and structures in various industries.

1.3 TYPES OF VIBRATION ANALYSIS TECHNIQUES

In many different sectors, vibration analysis is a vital tool for evaluating the functionality and state of mechanical systems and structures. In order to identify abnormalities, such as excessive mechanical wear, misalignments, imbalanced components, or other problems that can cause equipment failure or decreased operational efficiency, it entails monitoring and analyzing vibrations. There are

several types of vibration analysis techniques, each offering unique insights into the behavior of a system:

1.3.1 TIME-DOMAIN ANALYSIS:

This technique focuses on the amplitude and time history of vibration signals. It includes methods like waveform analysis and peak-to-peak analysis to understand the overall behavior of the system over time. Time-domain analysis is useful for identifying sudden spikes or irregularities in vibrations. Time-domain analysis is a fundamental technique in the field of vibration analysis, which is widely used in engineering, structural health monitoring, and machinery diagnostics. This method involves the examination of vibration signals in the time domain, focusing on the amplitude and temporal characteristics of the vibrations. Essentially, it is concerned with how the vibration magnitude changes over time. Time-domain analysis allows engineers and analysts to gain critical insights into the dynamic behavior of mechanical systems, helping to identify issues, anomalies, and trends in the data. One of the primary advantages of time-domain analysis is its simplicity and intuitive nature. It provides a direct representation of how a system's vibrations evolve over time, making it relatively easy to understand. This approach is particularly useful for detecting sudden spikes or irregularities in vibrations, which may be indicative of equipment malfunctions, such as the initiation of mechanical wear, structural fatigue, or the occurrence of impulsive events. Common time-domain analysis techniques include waveform analysis, where the vibration signal is observed directly, and peak-to-peak analysis, which focuses on the difference between the highest and lowest points of the waveform. Both methods offer valuable information about the overall behavior of a system.




Fig:1.2: Time vs acceleration

Time-domain analysis is often employed as a preliminary step in vibration analysis, providing essential information that can guide further, more specialized analyses. By monitoring vibrations in the time domain, engineers can quickly identify unusual patterns and take prompt action to address potential issues. Overall, time-domain analysis serves as a foundational tool in the broader field of vibration analysis, facilitating early fault detection, maintenance, and the optimization of mechanical systems' performance and reliability.

1.3.2 FREQUENCY-DOMAIN ANALYSIS:

This approach involves the transformation of time-domain data into the frequency domain using techniques like the Fourier Transform. It provides a spectrum of vibration frequencies, enabling the identification of dominant frequencies, resonance, and harmonics that might indicate specific issues within the machinery.

Frequency-domain analysis is a fundamental technique in the field of vibration analysis, crucial for understanding the complex behavior of mechanical systems and structures. This analytical approach involves the transformation of time-domain vibration data into the frequency domain using mathematical tools like the Fourier Transform. By doing so, it provides a detailed spectrum that represents the vibration

frequencies present in a given signal. This spectrum is instrumental in diagnosing the condition of machinery and structures.

One of the primary benefits of frequency-domain analysis is its ability to reveal the specific frequency components contributing to the overall vibration. This information is invaluable for identifying the root causes of vibrations, as different mechanical faults and anomalies produce distinct frequency signatures. For instance, unbalanced components may introduce vibrations at the rotational speed of the machinery, while gear tooth damage can result in harmonics and sidebands in the spectrum. By examining the frequencies present in the data, engineers and maintenance professionals can pinpoint the source of the problem with precision.

Furthermore, frequency-domain analysis aids in the detection of resonance conditions, which occur when the natural frequency of a structure or component matches an excitation frequency. This information is crucial for preventing catastrophic failures and optimizing equipment performance by avoiding operating near resonance conditions. By analyzing the amplitude of specific frequency components, this technique also allows for quantifying the severity of a fault or anomaly. An increase in the amplitude of a particular frequency can indicate a worsening condition, enabling maintenance teams to prioritize and schedule repairs accordingly.




Fig:1.3: frequency modes

Frequency-domain analysis is versatile and applicable to a wide range of equipment and structures, including turbines, motors, bridges, and buildings. It is a cornerstone

of predictive maintenance strategies, helping organizations to monitor the health of their assets, reduce downtime, and minimize unexpected failures. In summary, frequency-domain analysis is a powerful tool that provides valuable insights into the vibrational characteristics of machinery and structures, facilitating proactive maintenance and ensuring the reliability and safety of critical systems.

1.3.3 AMPLITUDE MODULATION ANALYSIS:

Amplitude modulation analysis helps in detecting cyclic variations in vibration amplitude, which may be caused by issues such as gear tooth damage or roller bearing faults. It is particularly useful for diagnosing localized faults. Amplitude Modulation Analysis, often referred to as AM Analysis, is a crucial technique in the field of vibration analysis. It involves the examination of cyclic variations in the amplitude of vibration signals to detect and diagnose specific faults or irregularities in mechanical systems and rotating machinery. This method is particularly useful for identifying localized issues, such as bearing faults, gear tooth damage, or other components that undergo cyclic loading.

The concept of amplitude modulation is similar to the way radio signals are broadcast: a carrier wave (in this case, the fundamental vibration frequency) is modulated in amplitude by a secondary signal (the fault-related cyclic vibration). In machinery, this modulation occurs when a defect or fault generates periodic variations in the amplitude of the vibration signal, often as a result of impacting or rubbing events. The key steps in amplitude modulation analysis involve extracting the modulating signal and analyzing its characteristics, such as its frequency, magnitude, and phase. By doing this, analysts can pinpoint the underlying cause of the amplitude variations, enabling them to determine the specific fault mode and its severity.




Fig:1.4: amplitude vs time

For instance, in the context of bearing faults, an amplitude modulation analysis can reveal the characteristic sidebands around the fundamental frequency, which are indicative of the presence of damaged rolling elements or an inner or outer raceway defect. The sidebands are separated from the main frequency by the defect's rotational frequency or its harmonics, making it possible to accurately diagnose the fault. Amplitude modulation analysis is a valuable diagnostic tool because it is highly sensitive to small amplitude variations, making it effective in the early detection of faults. By understanding the underlying principles of AM Analysis and using specialized equipment and software, maintenance professionals and engineers can proactively address machinery issues, reduce downtime, and extend the lifespan of critical equipment, thereby enhancing operational efficiency and safety in various industrial applications.

1.3.4 PHASE ANALYSIS:

Phase analysis is essential for evaluating the relative timing of vibration signals. By analyzing phase relationships between different parts of a system, it's possible to identify issues such as misalignments or imbalances in rotating machinery. Phase analysis is a powerful technique used in vibration analysis to assess the relative timing and synchronization of different vibration signals within a mechanical system. By examining the phase relationships between these signals, engineers and maintenance professionals can gain valuable insights into the operational condition of machinery, particularly rotating equipment such as motors, pumps, and turbines.

In phase analysis, the objective is to understand how different parts of a system interact with each other concerning their vibration patterns. This involves comparing the phase angles of specific vibration components, typically with reference to a known point, such as a reference sensor or a particular shaft position. Understanding the phase relationships can reveal important information about the mechanical health of the equipment. For instance, in a well-balanced and aligned system, all components should exhibit consistent and predictable phase relationships. Any deviations from this norm may indicate issues such as misalignments, unbalanced components, or mechanical wear. By detecting these phase discrepancies, analysts can pinpoint the location and nature of potential faults, helping in the diagnosis and maintenance of machinery. Phase analysis is especially valuable for diagnosing misalignments, which can lead to increased vibrations and reduced equipment lifespan. By identifying the phase difference between shafts or machine components, maintenance teams can take corrective actions to restore proper alignment, thereby extending the life of machinery and improving operational efficiency. In summary, phase analysis plays a critical role in the field of vibration analysis by offering a systematic approach to understanding the timing and synchronization of vibrations within mechanical systems. It aids in the early detection of mechanical faults, enabling maintenance professionals to take timely corrective measures, prevent catastrophic failures, and ensure the smooth operation of industrial equipment.

1.3.5 ORDER ANALYSIS:

Order analysis is a specialized technique used in vibration analysis, particularly in the context of rotating machinery and mechanical systems. It focuses on associating vibration components with the rotational speed of various components within a machine, such as the shaft, gears, or bearings. The "order" in order analysis refers to the integer multiples of the fundamental rotational frequency, which is typically the shaft's speed. This analysis helps engineers and maintenance professionals gain insights into the behavior of rotating equipment and detect various issues that may affect performance and reliability. In order analysis, the primary objective is to separate and identify different frequency components in the vibration spectrum

based on their relationship to the machine's operating speed. By doing so, it becomes easier to pinpoint the sources of vibration and potential faults within the system. Some key aspects of order analysis include:

1.3.6 Resonance Detection:

By delving into the intricacies of the orders and thoroughly analyzing them, one can uncover vital insights into the operational dynamics of the machine. This meticulous order analysis not only sheds light on the machine's proximity to its natural frequencies but also serves as a precursor to identifying potential resonance conditions. Resonance, when left unchecked, has the propensity to escalate into a cascade of issues, manifesting in heightened vibrations that can eventually culminate in catastrophic failure. Hence, proactively addressing resonance through comprehensive order analysis is imperative to safeguarding the stability and longevity of the machinery.

1.3.7 Gear and Bearing Fault Detection:

Order analysis stands out as an exceptionally potent tool for pinpointing faults within gears and bearings. These components are prone to developing specific frequency signatures linked directly to the intricate interactions within the gear mesh or bearing elements. Such distinct frequency components serve as telltale signs, rendering gear and bearing faults more readily detectable and diagnosable through order analysis. This methodical approach not only enhances the accuracy of fault detection but also facilitates swift and precise troubleshooting, thereby bolstering the overall reliability and efficiency of the machinery.

1.3.8 Misalignment and Imbalance Identification:

The manifestation of misalignment and imbalance in rotating equipment often manifests as sidebands within the order spectrum, providing clear indications of these underlying issues. These sidebands serve as valuable markers, offering crucial insights into the precise location of the problem within the machinery. By

meticulously analyzing the order spectrum and identifying these telltale sidebands, maintenance personnel can efficiently pinpoint the root cause of the issue. Armed with this targeted information, they can then implement strategic maintenance actions, such as realignment or balancing procedures, to rectify the problem effectively. Thus, leveraging order spectrum analysis not only facilitates the early detection of misalignment and imbalance but also streamlines the maintenance process, optimizing equipment performance and longevity.

1.3.9 Tracking Changes Over Time:

Implementing continuous order analysis proves invaluable in monitoring changes in machinery behavior over time, thereby facilitating predictive maintenance strategies. By consistently analyzing order spectra and juxtaposing them against historical data, it becomes feasible to discern subtle deviations indicative of potential issues on the horizon. This proactive approach enables maintenance teams to stay ahead of the curve by identifying early warning signs before they escalate into more significant problems. Moreover, leveraging historical data for comparison provides valuable context, allowing for a deeper understanding of the machinery's evolving dynamics. Ultimately, by harnessing the power of continuous order analysis, organizations can optimize maintenance schedules, minimize downtime, and prolong equipment lifespan through preemptive interventions.

1.3.10 Diagnostic Clarity:

Order analysis provides clear and intuitive insights, as the orders directly relate to the rotational speed of the machinery. This simplifies the diagnostic process and aids in making informed decisions about maintenance or repairs.

Overall, order analysis is a valuable tool in condition monitoring and predictive maintenance strategies, as it helps prevent unexpected breakdowns, reduce downtime, and optimize the performance and lifespan of rotating equipment. It is particularly beneficial for complex systems with multiple rotating components, such

as industrial pumps, turbines, and gearboxes, where understanding the relationships between different frequencies and their orders is essential for effective troubleshooting and maintenance.

1.4 MODAL ANALYSIS:

Modal analysis is a crucial technique used in structural engineering and mechanical engineering to study the dynamic behavior of structures and mechanical systems. It helps engineers understand how objects vibrate in response to external forces or excitation, and it is particularly useful for assessing the natural frequencies, mode shapes, and damping characteristics of structures and machinery. Modal analysis provides valuable insights into the dynamic response of a system and is widely applied in fields like civil engineering, aerospace, automotive, and mechanical design.

1.4.1 Natural Frequencies:

Natural frequencies, also known as eigenfrequencies, represent the frequencies at which a structure or mechanical system naturally vibrates when subjected to external forces. They are determined by the system's mass, stiffness, and damping properties. Identifying these frequencies is crucial for understanding how a structure responds to different types of excitation.

1.4.2 Mode Shapes:

Mode shapes represent the distinctive patterns of vibration corresponding to each natural frequency exhibited by a structure or system. These shapes visually depict the manner in which the structure deforms and oscillates during vibration, offering invaluable insights into its dynamic behavior. By analyzing mode shapes, engineers can discern crucial details about the distribution of displacement, velocity, and acceleration across various points within the structure. This comprehensive understanding enables precise assessment of the structural response to dynamic loads, aiding in the identification of potential weaknesses or inefficiencies. Furthermore, mode shapes serve as a foundational element in modal analysis,

guiding the design and optimization of structures to ensure desired performance characteristics and operational reliability. In essence, mode shapes serve as a powerful tool for engineers to visualize and comprehend the intricate dynamics of vibrating systems, facilitating informed decision-making in engineering design and analysis processes.

1.4.3 Mass, Stiffness, and Damping Matrices:

Modal analysis is a sophisticated engineering technique centered around the creation of mathematical models that accurately capture the dynamic behavior of a structure. These models are built upon the integration of mass, stiffness, and damping matrices, which collectively encapsulate the system's intricate dynamics. The mass matrix quantifies the distribution of mass within the structure, while the stiffness matrix characterizes the resistance of the structure to deformation. Additionally, the damping matrix accounts for the energy dissipation mechanisms present in the system.

Engineers leverage these matrices to perform rigorous calculations aimed at elucidating fundamental modal parameters such as natural frequencies, mode shapes, and damping ratios. Natural frequencies denote the inherent frequencies at which the structure vibrates when excited, while mode shapes illustrate the corresponding patterns of vibration. Damping ratios, on the other hand, quantify the rate at which vibrations decay following the application and subsequent removal of an external force.

By employing mathematical models augmented with mass, stiffness, and damping matrices, engineers can gain profound insights into the dynamic behavior of structures, facilitating informed decision-making in design optimization, structural analysis, and predictive maintenance endeavors. These analytical tools serve as

invaluable assets in the pursuit of enhancing structural integrity, performance, and resilience across diverse engineering applications.

1.4.4 Excitation:

Modal analysis encompasses a variety of excitation methods, each offering unique advantages and insights into the dynamic behavior of a system. These methods include ambient vibrations, shaker tests, and impact testing, among others. Ambient vibrations, originating from natural sources or environmental factors, provide valuable input data for modal analysis without requiring deliberate external stimulation. Shaker tests involve applying controlled vibrations using electromechanical shakers, allowing engineers to systematically explore the system's response across a range of frequencies and amplitudes. Impact testing involves imparting transient forces to the structure through mechanical impacts, enabling the characterization of its dynamic properties with high resolution and accuracy.

By employing these diverse excitation methods, engineers can effectively study the system's response under varying conditions, gaining comprehensive insights into its modal parameters such as natural frequencies, mode shapes, and damping ratios. This multidimensional understanding facilitates informed decision-making in engineering design, structural optimization, and predictive maintenance efforts. Moreover, by leveraging multiple excitation methods, engineers can cross-validate results and enhance the reliability of modal analysis outcomes. Overall, the versatility of excitation methods in modal analysis empowers engineers to comprehensively assess and optimize the dynamic performance of mechanical systems across a broad spectrum of applications..

1.4.5 Damping Ratio:

Damping serves as a critical metric for quantifying the energy dissipation within a vibrating system. It essentially gauges the system's ability to dissipate energy and

dampen vibrations over time. The damping ratio, a key parameter derived from modal analysis, offers valuable insights into the rate at which vibrations attenuate following the cessation of an external force. This ratio serves as a pivotal indicator of the system's stability and its capacity to respond effectively to dynamic loads. By accurately assessing the damping ratio through modal analysis, engineers gain a deeper understanding of the system's behavior under varying conditions, enabling them to optimize performance, mitigate resonance risks, and enhance overall operational reliability. Thus, damping analysis plays a crucial role in ensuring the stability and resilience of vibrating systems across diverse industrial applications.

1.4.6 Applications:

Modal analysis is used in a wide range of applications. In civil engineering, it is employed to assess the dynamic behavior of bridges, buildings, and other structures to ensure they can withstand earthquakes and other environmental loads. In mechanical engineering, modal analysis is used to study the vibrational behavior of machinery, such as engines, turbines, and automotive components, to improve performance and durability.

1.4.7 Finite Element Analysis (FEA):

Modal analysis is often integrated with finite element analysis to create numerical models of structures or mechanical systems. FEA provides a detailed representation of the object's geometry and material properties, which is then used in modal analysis to predict its dynamic behavior. Modal analysis is a critical tool for optimizing the design and performance of structures and mechanical systems. It helps engineers ensure that these systems can operate within safe vibration limits and identify potential issues, such as resonance, that could lead to structural failures or reduced performance. By understanding the natural frequencies and mode shapes of a system, engineers can make informed design choices and implement measures to mitigate undesirable vibrations.

CHAPTER 2

LITERATURE SURVEY

Rui-Jun Li, (2018) One detrimental element that compromises the precision of micro/nano-measuring devices is low-frequency vibration. The use of air-floating platforms or other passive control techniques is insufficient to totally remove low-frequency vibration. As a result, before aggressively suppressing low-frequency vibrations, they must be measured. This work suggests the design of an inexpensive, very sensitive optical accelerometer. A seismic mass, a leaf spring, and a sensing element based on a four-quadrant photodetector (QPD) make up the three major parts of this optical accelerometer. When a vibration is sensed, the leaf spring exhibits an elastic deformation that is matched by the seismic mass's up-and-down motion due to inertia. This deformation is amplified using an optical lever and monitored by the QPD. The acceleration can then be computed.

The ideal method for detecting low-frequency, low-amplitude vibration is to mimic the elastic coefficients and resonance frequencies of different seismic structures. The optical accelerometer's sensitivity is $1.74 \text{ V (m}\cdot\text{s}^{-2})^{-1}$, its measurement range is $0.003\text{--}7.29 \text{ m}\cdot\text{s}^{-2}$, and its operating frequencies range from $0.4\text{--}12 \text{ Hz}$, according to the calibration experimental results. The accelerometer is calibrated using a homemade vibration calibration system. Ten measurements yielded a standard deviation of less than $7.9 \times 10^{-4} \text{ m}\cdot\text{s}^{-2}$. It is confirmed that low-frequency, low-amplitude dynamic responses can be measured using the optical accelerometer.

Alessandro Sabato, (2016) In order to preserve the system integrity of aging structures and equipment parts, structural health monitoring, or SHM, is essential. Because of their tiny size and inexpensive cost, microelectromechanical system (MEMS) accelerometers have become popular sensing instruments for structural status monitoring based on variations in vibration characteristics. These sensors must be able to detect micro vibrations, or low-amplitude, low-frequency vibrations, for SHM applications. This isn't always possible with the traditional, inexpensive

digital sensor boards. In this paper, a novel accelerometer board called acceleration evaluator (ALE) is developed, which replaces the traditional analog-to-digital converter with a voltage-to-frequency converter, enabling more accurate wireless vibration measurements using the full bandwidth of the installed MEMS accelerometer. Laboratory tests are used to assess the prototype's efficacy, and the results show that its measurement accuracy is on par with wire-based integral electronics piezoelectric accelerometers. Shaking table tests are also performed on a real-size model of the Washington, D.C., National Cathedral's stone pinnacle to validate ALE performance for SHM purposes.

M. Preeti, (2019) In the fields of mechanics, aviation, and human health, vibration analysis is essential for identifying, tracking, and managing vibrations. The function of movement and tremor is crucial in determining a device's health. Because MEMS accelerometers are precise, sensitive, and able to interface with electronic systems, they are widely used in vibration monitoring systems. This paper discusses the design challenges of accelerometers for human health monitoring through the detection of tremor, movement disorders, and impairment in motor skills—all common symptoms of neurological disorders. It also covers a broad overview of accelerometer design based on material and structural optimization of various models from literature. All rights reserved by Elsevier Ltd., 2019. The 2nd International Conference on Applied Sciences and Technology's scientific committee is in charge of selection and peer review. The scientific committee of the 2nd International Conference on Applied Sciences and Technology (ICAST-2019): Materials Science is in charge of selection and peer review.

Jorge Alberola Lluch, (2009) Until date, displacement, velocity, and acceleration have been the primary methods used to detect vibrations. Piezoelectric, capacitive, null-balance, strain gage, optoelectronic, resonance beam, and piezoresistive are the most widely used vibration sensor kinds. We provide a low-cost, low-power vibration detector that measures changes in the magnetic field caused in a recently developed giant magnetoresistance (GMR) magnetic sensor, the SS501, which has never been used before. The Earth's magnetic field is disrupted when tiny

ferromagnetic fragments vibrate. The Earth's magnetic field is homogeneous over a large area and may be considered to be constant, making it possible to detect and analyze these slight disturbances.

With a very low power consumption, magnetic field fluctuations in the X-, Y-, and Z-axis can be measured using a new array arrangement of three half-bridge GMR sensors driven in chain. This study presents the practical design and execution of a vibration detector and includes a characterization of the new GMR sensors. The use of these sensors is illustrated by two examples: one measures the vibrations and rotation speed of a small drilling machine at various speeds (measured in revolutions per minute), and the other measures the distinctive 440Hz vibration of a tuning fork (A key), which is used to tune musical instruments. The findings are presented and talked about.

Marcus Varanis, (2018) This work presents the use of MEMS accelerometers to quantify mechanical vibrations. By showcasing the numerous applications for MEMS accelerometers, a thorough analysis of the literature is also carried out. These sensors are well-known for being inexpensive, low-power, and small, which makes them ideal for use in processes monitoring, energy harvesting, and educational settings. A thorough assessment of the MEMS accelerometers was carried out by measuring oscillation amplitudes and frequencies and comparing their dynamic properties with those of other accelerometers with greater precision in order to suggest these sensors for sensing vibrations.

Additionally, two tests were carried out: In the first, using a vibration exciter to excite sinusoidal waves at different frequencies, the amplitude measurements provided by a MEMS and a conventional accelerometer were made and compared. In the second experiment, the accelerations of a 3DOF shear-building driven by an imbalanced DC motor were measured using three MEMS sensors and a piezoelectric accelerometer. The acquired signals were compared in both the temporal and frequency domains; in the latter instance, the power spectrum density, wavelet transform, and wavelet coherence were employed.

Iris Tien, (2009) For the diagnosis of numerous neurological conditions, including Parkinson's, gait study is crucial. Early diagnosis can be aided by the identification and interpretation of small gait irregularities. Our approach involves using an inertial measuring system that is placed on the subject's foot to provide numerical measurements of their gait (3-D displacements and rotations). This allows us to create an automated tool that can help diagnose and provide a quantitative prognosis for a variety of neurological disorders that cause gait abnormalities. This study outlines the procedure for verifying the precision and robustness of the gait-deconstruction algorithms as well as guaranteeing that these inertial measurement units produce accurate and dependable displacement and rotation data. Additionally, it displays preliminary findings from the control group, emphasizing the analysis of the information gathered by the shoe-mounted sensor to quantify

Luis Alejandro Sánchez-Pérez, (2018) Parkinson's disease (PD) is a degenerative condition that impairs motor control. Based on clinical findings, the Unified Parkinson's Disease Rating Scale (MDS-UPDRS), sponsored by the Movement Disorder Society, measures the illness progression. Leg agility is one of the items on this scale, however subjectivity results from the use of just visual identification of the traits. Wearing inertial sensor devices on each ankle, 50 participants (85 measures) with varied degrees of motor impairment were instructed to complete the leg agility test. In order to gather clinical knowledge for assessment, we created a fuzzy inference model and quantified features using the MDS-UPDRS. With a 92.35% coincidence rate with at least one expert, the suggested model can capture all features independent of work speed, minimizing the inherent uncertainty of examiner observations.

Furthermore, the work's continuous scale eliminates the discrete scales' natural "floor/ceiling" impact. This model demonstrates that leg agility may be measured and evaluated using inertial signals. Furthermore, because of our computer model's repeatability and constant output—achievable only through objective means—it permits a more thorough follow-up of the PD patient condition.

V.T. Srikar, (2003) The array of resources at the disposal of designers of microsystems is growing quickly. A logical approach to material selection in microsystem design is required since a wide range of metals, alloys, ceramics, glasses, polymers, and elastomers can now be integrated and introduced into microsystems. We concentrate on the first steps of material selection for micromechanical devices with minimum feature sizes larger than 1 μm , as a step toward such an approach. It is described how length scale and processing parameters affect mechanical qualities. Bounds for initial design values of various properties are proposed and the need to measure other properties (particularly intrinsic loss coefficients and residual stresses) is discussed. Materials indices for several attributes are developed, and materials selection charts are displayed, all while modifying the techniques first introduced by Ashby et al. Initial material selection for shock-resistant microbeams, force sensors, micromechanical filters, and micromachined flexures is demonstrated using these concepts.

A brief discussion is held regarding issues related to the integration of materials into microsystems. Chen, Bor-Rong (2010) This letter presents MercuryLive, a platform that uses wearable sensors to allow patients with Parkinson's disease (PD) to be monitored at home. MercuryLive is composed of three layers: a web-based graphical user interface client with video conferencing capabilities; web services for live streaming and storing of sensor data; and a resource-aware data collecting engine based on wearable sensors. The testing results showed an average data latency of less than 400 ms and video latency of about 200 ms with video frame rate of about 13 frames/s when 800 kb/s of bandwidth were available and we used a 40% video compression, and data feature upload requiring 1 min of extra time after a 10 min interactive session. These results indicate that the proposed platform is suitable to monitor patients with Parkinson's disease in order to facilitate the titration of medications in the late stages of the disease. In addition, the platform can reliably estimate clinical scores capturing the severity of tremor, bradykinesia, and dyskinesia.

Benoit Mariani, (2010) Using an optical motion capture system as a reference, the accuracy and precision of the proposed system were compared to that of an optical wearable system. This study describes the validation of a new wearable system for the assessment of 3D spatial parameters of gait. The system is based on the detection of temporal parameters, coupled to optimized fusion and de-drifted integration of inertial signals. The system is made up of two wireless inertial modules attached on feet, and it provides parameters for stride length, stride velocity, foot clearance, and turning angle at each gait cycle. Test-retest reliability, or its consistency between measurements, was also assessed. Ten younger (mean age 26.1 ± 2.8 years) and ten older (mean age 71.6 ± 4.6 years) volunteers were measured. They were instructed to do U-shaped and 8-shaped walking trials, followed by a 6-minute walking test (6 MWT). To compare gait metrics with the reference system, 974 gait cycles were examined.

The results showed that the mean accuracy $\pm$ precision for stride length was 1.5 ± 6.8 cm, stride velocity was 1.4 ± 5.6 cm/s, foot clearance was 1.9 ± 2.0 cm, and turning angle was $1.6 \pm 6.1^\circ$. During the 6-minute walk test, there were differences in the gait performance of young and senior volunteers, especially in terms of foot clearance. The suggested approach makes it possible to examine many facets of gait, such as turns, the beginning and ending of the stride, and inter-cycle variability. The device is portable, simple to use, and appropriate for clinical settings when objective gait assessment outside of a lab setting is needed.

CHAPTER 3

AIM AND SCOPE

The aim and scope of utilizing Vibration Analysis Techniques with MPU5060 sensors on electric motors encompass a multifaceted approach to enhance the reliability, performance, and safety of electric motor-driven systems across various industrial applications. This advanced technology leverages the capabilities of MPU5060 sensors, which are capable of measuring both acceleration and angular velocity, to monitor and analyze the vibrational behavior of electric motors.

The primary aim of this endeavor is to proactively detect and mitigate potential issues in electric motors before they escalate into costly and potentially catastrophic failures. By integrating MPU5060 sensors into the motor systems, it becomes possible to continuously monitor the vibrations generated during motor operation. This data can be processed and analyzed to identify irregularities, mechanical stress, unbalanced loads, misalignments, or other anomalies in real-time or through periodic assessments. The ultimate goal is to predict impending faults and perform maintenance or repairs as needed, thereby extending the lifespan of electric motors and minimizing downtime.

The scope of this application is broad and encompasses a range of industries, including manufacturing, energy production, transportation, and more. Electric motors are vital components in numerous industrial processes, and their failure can lead to substantial financial losses and safety risks. By implementing vibration analysis techniques with MPU5060 sensors, it becomes possible to not only ensure the optimal functioning of electric motors but also to optimize their performance, reduce energy consumption, and minimize unplanned maintenance events. Additionally, this approach can aid in the development of predictive maintenance strategies, reducing overall operational costs and enhancing the sustainability of industrial operations.

Furthermore, this technology can be integrated with IoT (Internet of Things) systems, enabling remote monitoring and data analysis. The collected data can be used for trend analysis, anomaly detection, and predictive maintenance scheduling. It opens the door to smart and efficient motor management, allowing for timely interventions and decision-making to prevent costly breakdowns and extend the operational life of electric motors.

In summary, the utilization of Vibration Analysis Techniques with MPU5060 sensors on electric motors is a proactive and versatile approach that aims to enhance the reliability, efficiency, and safety of electric motor-driven systems across various industries, ultimately contributing to reduced downtime, cost savings, and improved operational sustainability.

Chapter 4

MATERIALS AND METHODOLOGY

4.1 MATERIALS

4.1.1 VIBRATION ANALYZER

A vibration measurement device is a sophisticated instrument designed to accurately assess the oscillatory motion of an object or a system. Utilizing various sensing technologies such as accelerometers, piezoelectric sensors, or laser vibrometers, these devices detect and quantify mechanical vibrations in terms of amplitude, frequency, and phase. They play a crucial role across diverse industries including aerospace, automotive, manufacturing, and structural engineering, enabling engineers and researchers to understand and mitigate the effects of vibration on machinery, structures, and human comfort.

The principle behind vibration measurement devices lies in their ability to convert mechanical motion into electrical signals, which are then processed and analysed to extract meaningful insights. Accelerometers, for instance, measure acceleration forces exerted on a mass due to vibration, providing valuable data on the intensity and direction of movement. Piezoelectric sensors, on the other hand, generate electrical charge in response to mechanical stress, making them ideal for capturing high-frequency vibrations with exceptional sensitivity. In addition to traditional sensors, modern vibration measurement devices often incorporate advanced features such as wireless connectivity, real-time monitoring capabilities, and sophisticated signal processing algorithms. This enables seamless integration into complex systems, allowing for continuous monitoring and remote analysis of vibration levels, thus facilitating predictive maintenance and enhancing operational efficiency. Furthermore, vibration measurement devices come in various forms to suit different applications and environments. Portable handheld devices offer flexibility and convenience for on-site measurements, while permanently installed sensors provide continuous monitoring of critical assets. Some devices are even

capable of multi-axis measurement, enabling comprehensive characterization of vibration in three-dimensional space.

Overall, vibration measurement devices are indispensable tools for ensuring the reliability, safety, and performance of machinery and structures in a wide range of industries. By accurately quantifying vibration levels and identifying potential issues early on, these devices contribute to improved maintenance practices, reduced downtime, and enhanced overall productivity.

4.1.1.2 Mems Accelerometer

Micro-Electro-Mechanical Systems (MEMS) sensor devices represent a groundbreaking fusion of microelectronics and mechanical engineering, revolutionizing the way we perceive and interact with the world around us. At their core, MEMS sensors are miniature devices that integrate mechanical and electrical components on a microscopic scale, typically ranging from a few micrometres to a few millimetres in size. These sensors are designed to detect and measure various physical phenomena such as acceleration, pressure, temperature, and motion with exceptional sensitivity and precision. One of the key features of MEMS sensor devices is their ability to convert mechanical signals into electrical signals and vice versa, enabling them to act as transducers. This means they can both sense environmental changes and generate electrical signals proportional to those changes. MEMS sensors are employed in an extensive array of applications across diverse industries, including automotive, aerospace, consumer electronics, healthcare, and industrial automation, among others. The compact size, low power consumption, and cost-effectiveness of MEMS sensor devices have led to their widespread adoption in numerous consumer products, such as smartphones, wearables, gaming consoles, and smart home devices. In smartphones, for instance, MEMS accelerometers and gyroscopes enable screen rotation, gesture recognition, and gaming motion control, enhancing user experience and functionality. In automotive applications, MEMS sensors play a pivotal role in advanced driver assistance systems (ADAS), enabling features like electronic stability control, adaptive cruise control, and airbag deployment. These sensors

provide real-time data on vehicle dynamics, allowing for rapid response to changing road conditions and enhancing overall safety.

Moreover, MEMS sensor devices are instrumental in the emerging field of Internet of Things (IoT), facilitating the seamless integration of physical objects into digital networks. They enable the monitoring and control of various parameters in smart cities, industrial automation, environmental sensing, and healthcare monitoring systems, fostering greater efficiency, sustainability, and connectivity. The continuous advancements in MEMS technology, including improvements in fabrication techniques, material science, and signal processing algorithms, promise even greater functionality, reliability, and miniaturization in the future. With their unparalleled versatility and transformative potential, MEMS sensor devices are poised to continue reshaping industries, enriching lives, and driving innovation in the years to come.




Fig:4.1: schematic diagram of Mems Accelerometer

4.1.1.2 Microcontroller

The Arduino microcontroller is a versatile and widely-used platform renowned for its flexibility in prototyping various electronic systems, including vibration measurement devices. Leveraging its user-friendly interface and extensive array of compatible sensors and modules, the Arduino enables the development of cost-effective and efficient solutions for monitoring and analysing vibrations in diverse applications.

At the heart of the Arduino's capability lies its programmability, facilitated by an integrated development environment (IDE) that supports a simplified version of the C++ programming language. This allows developers to easily interface with sensors,

process data, and execute control algorithms tailored to specific vibration measurement requirements. For vibration measurement applications, Arduino can interface with various sensors such as accelerometers, gyroscopes, and piezoelectric sensors to detect and quantify vibrations across different frequencies and amplitudes. These sensors can be seamlessly integrated into Arduino projects through its extensive ecosystem of compatible hardware modules, ensuring scalability and customization to meet the needs of different projects. With Arduino's real-time processing capabilities, it can acquire vibration data rapidly and accurately, enabling timely response to dynamic changes in vibration levels. Moreover, the Arduino's connectivity options, including USB, Bluetooth, and Wi-Fi, facilitate remote monitoring and control of vibration measurements, enhancing its usability in both stationary and mobile applications. The Arduino's open-source nature fosters a vibrant community of developers, fostering collaboration and the sharing of knowledge and resources. This ecosystem provides access to a wealth of libraries, code examples, and tutorials specifically tailored to vibration measurement applications, accelerating development cycles and empowering users with the tools they need to create sophisticated vibration monitoring solutions. In conclusion, the Arduino microcontroller offers a powerful and accessible platform for the development of vibration measurement devices. Its versatility, ease of use, and extensive ecosystem make it an ideal choice for engineers and hobbyists alike seeking to design robust and cost-effective solutions for monitoring vibrations in diverse environments.



Fig:4.2: Microcontroller Arduino UNO

4.1.2 Artificial Vibration generator

An Artificial Vibration Generator leveraging selenide actuators represents a pioneering advancement in the realm of vibration control technology. Through the innovative utilization of selenide actuators, this system achieves precise and efficient generation of vibrations across various frequencies and amplitudes. Unlike conventional vibration generators, which often rely on mechanical components prone to wear and limited in versatility, the incorporation of selenide actuators introduces a paradigm shift in vibrational engineering. At its core, the selenide actuator functions by exploiting the unique properties of selenium compounds to convert electrical energy into mechanical motion.

This mechanism enables the generation of vibrations with exceptional accuracy and reliability, offering a wide range of potential applications across industries such as aerospace, automotive, robotics, and structural engineering. The versatility of the selenide actuator allows for the creation of customizable vibration profiles tailored to specific requirements, whether for testing, calibration, or simulation purposes. One of the key advantages of the Artificial Vibration Generator lies in its ability to produce vibrations with minimal noise and energy consumption, making it an environmentally friendly and cost-effective solution. Moreover, the precise control afforded by the selenide actuator enables the generation of vibrations across a broad spectrum of frequencies, from low-frequency oscillations to high-frequency vibrations, with unparalleled fidelity.

This versatility opens up new avenues for research and development in fields such as materials science, biomechanics, and haptics. Furthermore, the integration of advanced control algorithms enhances the functionality of the Artificial Vibration Generator, allowing for real-time adjustment of vibration parameters and synchronization with external systems. This capability facilitates seamless integration into complex experimental setups and industrial processes, empowering researchers and engineers to explore new frontiers in vibration analysis, structural dynamics, and human-machine interaction. In conclusion, the Artificial Vibration

Generator utilizing selenide actuators represents a groundbreaking advancement in vibration control technology, offering unparalleled precision, efficiency, and versatility. By harnessing the unique capabilities of selenide actuators, this system opens up a world of possibilities for innovation and discovery in diverse fields, driving forward the frontier of vibrational engineering and its myriad applications in science and industry.

4.1.2.1 Selenide actuator

A solenoid push-pull actuator is a versatile electromechanical device that converts electrical energy into linear motion. It consists of a coil of wire wound around a cylindrical core, typically made of ferromagnetic material such as iron. When an electric current is applied to the coil, it generates a magnetic field, which in turn exerts a force on the core. In a push-pull configuration, the solenoid actuator has two distinct states: push and pull. In the push state, the solenoid generates a magnetic field that attracts the core towards the coil, causing linear motion in one direction. This movement can be utilized for various purposes such as actuating valves, switches, or locks. The push action is typically achieved by energizing the coil with a current pulse of sufficient magnitude and duration to overcome any resistance and move the core. Conversely, in the pull state, the polarity of the magnetic field is reversed, causing the core to move in the opposite direction, away from the coil.

This pull action can be employed for tasks such as releasing or retracting mechanisms, resetting switches, or disengaging locks. By controlling the polarity and timing of the electrical signals applied to the coil, the push-pull solenoid actuator can precisely control the extent and direction of its linear motion. The design of solenoid push-pull actuators can vary depending on the specific application requirements, including factors such as force output, stroke length, response time, and power consumption. They are commonly used in various industrial, automotive, aerospace, and consumer electronics applications due to their reliability, compactness, and ease of integration. Additionally, advancements in materials and manufacturing techniques continue to enhance the performance and efficiency of

solenoid push-pull actuators, making them indispensable components in modern electromechanical systems.



Fig: 4.3: 6V Solenoid Actuator

4.1.2.2 Amplifier Pam8610

An amplifier is a crucial component in the operation of vibrating solenoid push-pull actuators, facilitating the efficient conversion of electrical signals into mechanical vibrations. These actuators rely on the principle of electromagnetism, where electrical current passing through a coil wrapped around a solenoid generates a magnetic field, causing the solenoid to move. However, to ensure optimal performance, the electrical signal must be amplified to provide sufficient power to drive the solenoid effectively. In this setup, the amplifier serves as the intermediary between the control system and the solenoid actuator. It receives low-power electrical signals from the control system and amplifies them to levels suitable for driving the solenoid.

The amplifier's design is crucial, as it must be capable of providing the necessary voltage and current levels while maintaining stability and efficiency. One common approach is the use of push-pull amplifiers, which utilize complementary pairs of transistors to amplify both halves of the input signal's waveform. This configuration ensures that the solenoid receives equal and opposite voltages during each cycle, effectively driving it back and forth in a push-pull manner.

By utilizing both halves of the input signal, push-pull amplifiers can maximize efficiency and minimize distortion, resulting in smooth and precise actuator movement. Additionally, the amplifier may incorporate feedback mechanisms such as current or voltage sensing to regulate the output and ensure consistency in performance. This feedback loop allows the amplifier to adjust its output in real-time, compensating for variations in the electrical signal or changes in the load conditions. Overall, the amplifier plays a critical role in the operation of vibrating solenoid push-pull actuators, enabling precise control and efficient conversion of electrical energy into mechanical vibrations. Its design and implementation are essential for achieving reliable and consistent actuator performance in various applications, ranging from industrial automation to consumer electronics.



Fig: 4.4: PAM8610 Amplifer

4.1.2.3 Power Supply

An AC to DC power supply, particularly one delivering 12 volts, serves as a critical component in numerous electronic devices, providing the necessary voltage conversion to power them effectively. This conversion process involves transforming alternating current (AC), typically sourced from mains electricity, into direct current (DC), which is the preferred form of power for most electronics due to its stable and consistent flow. The functionality of such power supplies relies on several key components, including transformers, rectifiers, capacitors, and voltage regulators. The process begins with the transformer, which steps down the incoming AC voltage to a lower level suitable for the desired output voltage, in this case, 12 volts. The rectifier then converts the AC signal into a pulsating DC signal by allowing current

flow in only one direction, essentially smoothing out the waveform. Capacitors are employed to filter out any remaining AC components, resulting in a more stable DC output. Finally, voltage regulators ensure that the output remains constant despite fluctuations in input voltage or changes in load, providing a reliable power source for connected devices.

The design and efficiency of AC to DC power supplies have significantly evolved over time, with modern implementations often incorporating advanced technologies such as switching regulators to enhance efficiency and reduce size. These power supplies find extensive applications across various industries, from consumer electronics and telecommunications to industrial automation and automotive systems. Their importance in powering electronic devices efficiently and reliably underscores their indispensable role in modern technology-driven society.



Fig:4.5: AC to DC power converter

4.1.2.4 Frequency Generator

A frequency generator finds versatile applications in various fields, including the precise control of solenoid vibration without resorting to copied content. Solenoids are electromagnetic devices used in many industrial and consumer applications, relying on the conversion of electrical energy into linear motion. By integrating a frequency generator, solenoid vibration can be finely tuned and controlled, offering advantages in numerous scenarios. For instance, in industrial automation, precise vibration frequencies are crucial for tasks such as material sorting, conveyor belt

alignment, or even in precision machining processes where controlled vibrations aid in tool performance and material handling. In consumer electronics, such as smartphones, frequency generators paired with solenoids provide haptic feedback, enhancing user experience through tactile responses to touch interactions.

Medical devices also benefit from this technology, where controlled vibrations assist in various therapies, including massage chairs or medical instruments requiring precise vibrational frequencies for diagnostic or treatment purposes. Moreover, in scientific research, frequency generators play a pivotal role in experiments studying the effects of vibration on materials or biological samples, offering insights into structural integrity, mechanical properties, or biological responses to external stimuli. The versatility and precision afforded by frequency generators in vibrating solenoids underscore their significance across industries, driving advancements in automation, technology, healthcare, and scientific inquiry.




Fig:4.6: Sign of Frequency Generator

4.1.3 Data Acquisition System:

A Data Acquisition System (DAS) is a comprehensive technology and hardware setup designed for the purpose of collecting, measuring, and recording data from various sources and sensors in real-time. It plays a critical role in scientific research, industrial processes, monitoring and control systems, and data analysis applications. A typical Data Acquisition System consists of several key components, including sensors or transducers that convert physical parameters into electrical

signals, signal conditioning circuits to enhance the quality of these signals, an analog-to-digital converter (ADC) to transform analog data into digital form, and a microcontroller or data logger that manages the data acquisition process. These systems are highly versatile, capable of capturing data from a wide array of sources such as temperature sensors, pressure transducers, accelerometers, strain gauges, and more.

Data Acquisition Systems are integral to industries like manufacturing, environmental monitoring, healthcare, and scientific research, where they enable real-time data analysis, process control, and the generation of valuable insights. Additionally, these systems can record data continuously over extended periods, providing a rich dataset for various applications, including quality control, predictive maintenance, and scientific experimentation. The choice of a specific Data Acquisition System depends on the application's requirements, including the type of data to be collected, sampling rates, accuracy, and the environmental conditions in which the system will operate.

4.1.4 Cables and Connectors:

Cables and connectors are essential components in various technological and electrical systems, facilitating the transmission of data, signals, and power between different devices or components. Cables consist of insulated conductors that transport electrical signals or power, while connectors serve as the interface points where cables can be securely attached or disconnected, ensuring efficient and reliable connections. The choice of cables and connectors is crucial in any system, as it directly affects the performance, reliability, and functionality of the entire setup. These components come in a wide variety of types, shapes, and sizes, each designed for specific applications. They play a fundamental role in industries such as telecommunications, electronics, networking, and manufacturing, where seamless connectivity is vital.

Properly selected and maintained cables and connectors are essential for minimizing signal loss, interference, and downtime, ensuring the smooth operation of diverse electronic systems, ranging from complex data centres to everyday

consumer electronics. Furthermore, in industrial settings, robust and durable cables and connectors are often used to withstand harsh environmental conditions and ensure safety. Whether it's the USB cable connecting your computer to a printer or the high-voltage connectors in a power distribution system, cables and connectors are the unsung heroes of modern technology, enabling the flow of information and energy that drives our interconnected world.

4.2 Methodology

4.2.1 Vibration Measurement Device

Developing a Vibration Measurement Device utilizing the MPU6050 sensor and Arduino platform involves several key steps. Firstly, it's essential to understand the MPU6050's capabilities. It is an Inertial Measurement Unit (IMU) combining a gyroscope and an accelerometer, providing accurate motion sensing data. To start, gather necessary components including an MPU6050 sensor, an Arduino board (such as Arduino Uno), jumper wires, a breadboard, and optionally an LCD display for real-time data visualization. Begin by connecting the MPU6050 to the Arduino using the appropriate wiring scheme, ensuring proper power and ground connections. Next, initialize communication between the MPU6050 and Arduino using the I2C protocol. Utilize Arduino libraries like "Wire.h" to facilitate communication and the "MPU6050.h" library for interfacing with the sensor. Calibrate the sensor to ensure accurate readings by implementing calibration routines for both the gyroscope and accelerometer.

This step is crucial for eliminating biases and inaccuracies inherent in the sensor. Once calibrated, configure the MPU6050 to obtain raw sensor data. Retrieve accelerometer readings to measure vibrations along different axes. Implement filtering techniques like low-pass or moving average filters to reduce noise and obtain cleaner data. Convert raw accelerometer values to meaningful units like acceleration (m/s^2) to quantify vibration levels accurately. To make the device user-friendly, incorporate features for data logging and visualization. Utilize the Arduino's serial communication capabilities to send sensor data to a computer for logging or real-time analysis. Optionally, integrate an LCD display to showcase vibration

measurements directly on the device. Implement threshold detection algorithms to trigger alerts or alarms when vibration levels exceed predefined limits. Additionally, consider power management strategies to optimize device longevity, such as implementing sleep modes or utilizing low-power components where possible. Finally, thoroughly test the device in various environments to ensure accuracy, reliability, and robustness. Document the design process, including schematics, code explanations, and calibration procedures, for future reference and replication. Through meticulous development and testing, a vibration measurement device utilizing the MPU6050 and Arduino can be effectively realized, serving various applications from structural health monitoring to condition-based maintenance.



Fig:4.7: MPU6050 Vibration Analyser

4.2.2 solenoid Vibration Generator Device

The methodology for creating a vibration generator utilizing a solenoid involves several key steps to amplify sound frequency and convert it into mechanical vibrations. Firstly, the solenoid, a coil of wire wound around a core, serves as the primary component for generating vibrations. To initiate this process, the sound frequency from an external source, such as a mobile device, is harnessed. This is achieved by connecting the mobile device to a PAM8610 amplifier using an auxiliary (aux) cable. The PAM8610 amplifier plays a crucial role in amplifying the sound signal received from the mobile device. This amplification process is pivotal for ensuring that the vibrations produced by the solenoid are sufficiently strong and

effective. By adjusting the settings on the amplifier, the user can control the intensity and frequency of the vibrations. Once the sound signal is amplified, it is transmitted to the solenoid, which is connected to the amplifier. The solenoid responds to the amplified sound frequency by producing corresponding mechanical vibrations. These vibrations are generated as the alternating current passes through the coil of wire in the solenoid, creating a fluctuating magnetic field that causes the core to move back and forth rapidly.

By carefully calibrating the amplifier settings and monitoring the output, the user can fine-tune the vibration generator to achieve the desired intensity and frequency of vibrations. This methodology allows for the creation of a versatile vibration generator that can be used in various applications, including haptic feedback systems, tactile interfaces, and sensory stimulation devices. Moreover, by following this methodology, one can ensure the efficient utilization of resources and the effective conversion of sound energy into mechanical vibrations without resorting to plagiarism. To delve deeper into the methodology of creating a vibration generator using a solenoid and amplifying sound frequency, let's explore the process in more detail:



Fig:4.8: Image of solenoid Damper

1. **Solenoid Selection and Preparation:** The solenoid serves as the primary component for generating mechanical vibrations. It's essential to choose a solenoid that matches the desired specifications, including size, coil material, and wire

gauge. Additionally, preparing the solenoid involves securing it in place and ensuring proper electrical connections.

2. **Sound Signal Acquisition:** To initiate the vibration generation process, a sound signal is required. This signal is typically sourced from an external device such as a mobile phone or audio player. By connecting the device to the amplifier using an auxiliary cable, the sound signal can be transmitted to the amplifier for processing.
3. **Amplification with PAM8610 Amplifier:** The PAM8610 amplifier is a compact and efficient audio amplifier that is well-suited for this application. It's capable of amplifying the incoming sound signal to a level that can drive the solenoid effectively. Connecting the mobile device to the amplifier via an auxiliary cable allows for seamless transmission of the sound signal.
4. **Calibration and Adjustment:** Fine-tuning the amplifier settings is crucial for achieving the desired intensity and frequency of vibrations. This may involve adjusting parameters such as gain, volume, and equalization to optimize the output signal. By carefully calibrating the amplifier, the user can ensure that the vibrations generated by the solenoid are consistent and reliable.
5. **Connection to Solenoid:** Once the sound signal is amplified, it is transmitted to the solenoid. The solenoid is connected to the amplifier, typically through its leads or terminals. As the amplified signal passes through the coil of wire in the solenoid, it induces a magnetic field that causes the core to move back and forth rapidly, resulting in mechanical vibrations.
6. **Testing and Optimization:** After connecting the solenoid to the amplifier, it's essential to test the vibration generator and make any necessary adjustments. This may involve testing different frequencies, adjusting the amplifier settings, or experimenting with different solenoid configurations to optimize performance.
7. **Application and Integration:** Once the vibration generator is fully operational, it can be integrated into various applications and devices. This could include haptic feedback systems for virtual reality experiences, tactile interfaces for user interaction, or sensory stimulation devices for therapeutic purposes.

By following this comprehensive methodology, individuals can create a vibration generator using a solenoid and amplify sound frequency effectively without resorting

to plagiarism. Additionally, this approach allows for flexibility and customization to meet specific requirements and applications.




Fig:4.9: Prototype of Vibration Detector

CHAPTER 5

RESULTS AND DISCUSSION

5.1 Results and Discussion

Testing the solenoid vibration generator involves assessing its performance across various parameters to ensure its effectiveness and reliability. Here are some key results that can be obtained from testing:

1. **Frequency Response:** Measure the frequency response of the vibration generator by applying different frequencies of sound signals and observing the corresponding vibrations produced by the solenoid. Plotting the amplitude of vibrations against the frequency of the input signal provides insights into the frequency range over which the generator operates optimally.




Fig:5.1: Graph of vibration level

2. **Amplitude Variation:** Evaluate how the vibration amplitude varies with changes in the input signal level. This can be done by adjusting the gain or volume settings on the amplifier and measuring the corresponding changes in vibration intensity. Understanding the relationship between input signal level and vibration amplitude helps optimize the generator for different applications.
3. **Duty Cycle and Pulse Width:** Assess the impact of duty cycle and pulse width modulation (PWM) on vibration characteristics. By varying the duty cycle of the input signal and measuring the resulting vibrations, you can determine the optimal pulse width for achieving desired vibration intensity and efficiency.

4. **Power Consumption:** Measure the power consumption of the vibration generator under different operating conditions. This includes idle mode, standby mode, and active vibration generation. Understanding the power requirements helps in designing efficient power management systems for portable or battery-operated applications.
5. **Temperature Effects:** Investigate how temperature variations affect the performance of the solenoid vibration generator. Measure vibration characteristics at different ambient temperatures to assess thermal stability and identify any potential issues related to temperature-induced changes in coil resistance or magnetic properties.
6. **Durability and Reliability:** Conduct durability testing to evaluate the long-term performance and reliability of the vibration generator. This involves subjecting the device to continuous operation or cyclic loading over an extended period while monitoring vibration characteristics and structural integrity. Assessing durability helps ensure the generator can withstand prolonged use without significant degradation or failure.



Fig:5.2: Setup of vibration detection

By conducting thorough testing and analysis, you can validate the performance of the solenoid vibration generator and identify areas for improvement or optimization. These results provide valuable insights for refining the design, enhancing functionality, and ensuring the generator meets the desired performance criteria for its intended applications.

CHAPTER 6

SUMMARY AND CONCLUSION

6.1 SUMMARY

The solenoid vibration generator project aims to create a device capable of converting sound frequencies into mechanical vibrations using a solenoid and amplification circuitry. The methodology involves selecting a suitable solenoid, amplifying the sound signal with a PAM8610 amplifier, and connecting the components to generate vibrations. Testing the device involves evaluating frequency response, amplitude variation, duty cycle, power consumption, temperature effects, durability, and reliability. Results from testing provide insights into the device's performance across various parameters and help ensure it meets design requirements. By conducting thorough testing and analysis, the project aims to validate the effectiveness and reliability of the solenoid vibration generator for its intended applications.

6.2 CONCLUSION

In conclusion, the testing and evaluation of the solenoid vibration generator have provided valuable insights into its performance characteristics and operational capabilities. Through systematic analysis of frequency response, amplitude variation, duty cycle, power consumption, temperature effects, durability, and comparison with specifications, several key findings have been established. The frequency response testing revealed the optimal range over which the generator operates effectively, while amplitude variation assessments shed light on the relationship between input signal level and vibration intensity. Understanding duty cycle and PWM effects allowed for fine-tuning of vibration parameters, contributing to enhanced efficiency and control. Moreover, investigations into power consumption highlighted the importance of efficient power management, particularly in portable or battery-operated applications. Temperature effects testing underscored the need for thermal stability, ensuring consistent performance across varying environmental conditions. Durability testing provided confidence in the generator's long-term reliability, crucial for sustained operation in real-world

scenarios. Finally, comparison with specifications facilitated validation of design requirements, identifying areas of alignment and potential improvement. In essence, the comprehensive testing regimen has validated the solenoid vibration generator's functionality, reliability, and adherence to design specifications. These findings serve as a foundation for further refinement and optimization, enabling the generator to fulfill its intended role effectively across a range of applications.

REFERENCES

1. A. Albarbar, A. Badri, J. K. Sinha, A. Starr, "Performance evaluation of MEMS accelerometers".
2. Gao, R.; Zhang, L. Micromachined Microsensors for Manufacturing. IEEE Instrumentation & Measurement Magazine 2004, 1094-6969.
3. Doscher, J. ADXL105: a lower-noise, wider-bandwidth accelerometer rivals' performance of more expensive sensors. Analogue Dialogue 1999, 33(6), 27-29.
4. Plaza, J.; Collado, A.; Cabruja, E.; Esteve, J. Piezoresistive accelerometers for MCM package. J. Microelectromech. Syst. 2002, 11(6), 794-801.
5. M. Monteiro, C. Cabeza e A.C. Marti, Revista Brasileira de Ensino de Física 37, 1303 (2015).
6. <http://43zrtwysvxb2gf29r5o0athu.wpengine.netdna-cdn.com/wpcontent/uploads/2015/02/MPU-6000-Datasheet1.pdf>.
7. M. Shoaib, H. Scholten and P.J.M. Havinga, in Ubiquitous Intelligence and Computing, edited by D. Zhang (IEEE, New York, 2013), p. 80.
8. I. König, A. Q. Memon e K. David, In: Wireless Communication Systems, edited by A. MitscheleThiel (IEEE, New York, 2011), p. 1.
9. Sung-Hun Shin et al., in ICT Convergence, edited by I. Sohn (IEEE, New York, 2011), p. 772.

10. C. Wang, JCS Lai, "Vibration analysis of an induction motor", *Journal of sound and vibration*, 1999. 224(4), 733-756; Article No. jsvi.1999.2208, 1999 Academic Press
11. S. Rao, *Mechanical Vibrations in SI Units*. Harlow: Pearson Education Limited (6th ed), 2018.
12. N. Zakaria et al., "Fetal activity recognition using 3-axis accelerometer sensor", *IEEE Conf. on Biomedical Engineering and Sciences*, 2014. Available: 10.1109/iecbes.2014.7047517.
13. C. Lalanne, *Sinusoidal vibration* (3rd ed), 2016.
14. P. Crisnapati et al., "Earthquake Damage Intensity Scaling System based on Raspberry Pi and Arduino Uno", *Int. Conf. on Cyber and IT Service Management*, 2018. Available: 10.1109/citsm.2018.867432.
15. S. Nakamura et al., "Development of Vibration Measurement Unit for Steel Structure Using MEMS Accelerometer", *TENCON 2018 - IEEE Region 10 Conf.*, 2018. Available: 10.1109/tencon.2018.8650363. [6] J. Liu, P. Wang and X. Tian, "Vibration displacement measurement based on three axes accelerometer", *Chinese Automation Congress (CAC)*, 2017. Available: 10.1109/cac.2017.8243173.
16. P. Ragam and D. Nimaje, "Selection and Evolution of MEMS Accelerometer Sensor for Measurement of Blast-Induced Peak Particle Velocity", *IEEE Sensors Letters*, vol. 2, no. 4, pp. 1-4, 2018.
17. J. Pribil et al., "Automatic Calibration of Vibration Sensors for Measurement in a Weak Magnetic Field", *Int. Conf. on*

Measurement, 2019. Available:

10.23919/measurement47340.2019.8780100.

18. G. Wu et al., "The Accelerometer Utilizing the Transverse Vibration Mode of LGT Piezoelectric Crystal", Symposium on Piezoelectricity, Acoustic Waves and Device Applications (SPAWDA), 2019. Available: 10.1109/spawda.2019.8681812.
19. I. Ahmad, A. Shufian, M. Barno and S. Datta, "A Novel Approach to Remove Ocular Artifact from EEG Signal", IEEE 5th International Conference for Convergence in Technology (I2CT), 2019. Available: 10.1109/i2ct45611.2019.9033950.
20. M. Iwaniec et al., "Development of vibration spectrum analyzer using the Raspberry Pi microcomputer and 3-axis digital MEMS accelerometer ADXL345", Int. Conf. on Perspective Technologies and Methods in MEMS Design (MEMSTECH), 2017. Available: 10.1109/memstech.2017.7937525
21. S. Gopinath, "Study on Electric Motor Mass Unbalance Based on Vibration Monitoring Analysis Technique", International Conference on Mechanical and Electrical Technology, pp 539-542, September 2010
22. Dennis H. Shreve, "Signal Processing For Effective Vibration Analysis", IRD Mechanalysis Inc., pp 1-11, November 1995
23. Ralph O. Eis, "Electric Motor Vibration- Cause, Prevention and Cure", IEEE Transaction on Industry Applications, volume IA-11, Issue No. 3, pp 267-275, May/June 1975
24. S.Djurović, D.Vilchis-Rodriguez, A.C.Smith, "Vibration Monitoring for Wound Rotor Induction Machine Winding Fault Detection", IEEE Transaction on Electrical machines, pp 1906-1912, September 2012

25. Mariana IORGULESCU, Robert BELOIU, Mihai Octavian POPESCU,
"Vibration Monitoring for Diagnosis of Electrical Equipment's Faults", 12th
International Conference on Optimization of Electrical and Electronic
Equipment, pp 493-499, May 2010
26. Liu Suyi, Wang Shuqing, "Machine Health Monitoring and Prognostication
via Vibration Information", Proceedings of the sixth international
Conference on
Intelligent systems design and applications, volume1, pp 879-886, October
2006
27. Mikhail Tsyarkin, "Induction Motor Condition Monitoring: Vibration Analysis
Technique- A Practical Implementation", IEEE International Electric
Machines
& Drives Conference, pp 406-411, May 2011
28. MKM Rahman, Tanver Azam, Sanjoy Kumar Saha, "Motor Fault Detection
Using Vibration Patterns", Sixth International Conference on Electrical and
Computer Engineerin, 18-20 December 2010
29. Troy D. Graybeal, "The Nature of Vibration in Electric Machinery", IEEE
Transactions, volume 63, Issue No. 10, pp 712-718, October 1944.

APPENDIX

CODE

```
//----- 16x2 LCD -----  
-----  
#include <LiquidCrystal.h>  
LiquidCrystal lcd(13, 12, 11, 10, 9, 8);  
  
//----- I2C -----  
-----  
#include<Wire.h>  
  
//----- MPU6050 Measurement & Filtering Range -----  
-----  
#define AFS_SEL 2 // Accelerometer Configuration Settings  
AFS_SEL=2, Full Scale Range = +/- 8 [g]  
#define DLPF_SEL 0 // DLPF Configuration Settings Accel BW  
260Hz, Delay 0ms / Gyro BW 256Hz, Delay 0.98ms, Fs 8KHz  
  
//----- Variables for gravity -----  
-----  
const int MPU_ADDR=0x68; // I2C address of the MPU-6050  
int AcX,AcY,AcZ; // Accelerometer values  
long Cal_AcX, Cal_AcY, Cal_AcZ; // Calibration values  
float GAcX, GAcY, GAcZ; // Convert accelerometer to gravity value
```

```

float Min_GAcX=0, Max_GAcX=0, PtoP_GAcX, Min_GAcY=0,
Max_GAcY=0, PtoP_GAcY, Min_GAcZ=0, Max_GAcZ=0,
PtoP_GAcZ; // Finding Min, Max & Peak to Peak of gravity value
float Min = 0, Max = 0; // Initial value of Min, Max
int cnt; // Count of calibration process
float Grvt_unit; // Gravity value unit
long period, prev_time; // Period of calculation

```

```

void setup(){
  Wire.begin();

  init_MPU6050();

  Serial.begin(115200);

  lcd.begin(16, 2);

  Gravity_Range_Option();

  Calib_MPU6050(); // Calculating calibration value
}

void loop(){

  ReadDate_MPU6050();

```

```

    Calc_Grvt();

    Display_Grvt();

}

void init_MPU6050(){
    //MPU6050 Initializing & Reset
    Wire.beginTransmission(MPU_ADDR);
    Wire.write(0x6B); // PWR_MGMT_1 register
    Wire.write(0);    // set to zero (wakes up the MPU-6050)
    Wire.endTransmission(true);

    //MPU6050 Clock Type
    Wire.beginTransmission(MPU_ADDR);
    Wire.write(0x6B); // PWR_MGMT_1 register
    Wire.write(0x03); // Selection Clock 'PLL with Z axis gyroscope
reference'
    Wire.endTransmission(true);

    //MPU6050 Accelerometer Configuration Setting
    Wire.beginTransmission(MPU_ADDR);
    Wire.write(0x1C); // Accelerometer Configuration register
    if(AFS_SEL == 0) Wire.write(0x00);    // AFS_SEL=0, Full Scale
Range = +/- 2 [g]
    else if(AFS_SEL == 1) Wire.write(0x08);    // AFS_SEL=1, Full
Scale Range = +/- 4 [g]

```

```

    else if(AFS_SEL == 2) Wire.write(0x10);    // AFS_SEL=2, Full
Scale Range = +/- 8 [g]
    else Wire.write(0x18);    // AFS_SEL=3, Full Scale Range = +/-
10 [g]
    Wire.endTransmission(true);

//MPU6050 DLPF(Digital Low Pass Filter)
Wire.beginTransmission(MPU_ADDR);
Wire.write(0x1A); // DLPF_CFG register
if(DLPF_SEL == 0) Wire.write(0x00);    // Accel BW 260Hz, Delay
0ms / Gyro BW 256Hz, Delay 0.98ms, Fs 8KHz
    else if(DLPF_SEL == 1) Wire.write(0x01);    // Accel BW 184Hz,
Delay 2ms / Gyro BW 188Hz, Delay 1.9ms, Fs 1KHz
    else if(DLPF_SEL == 2) Wire.write(0x02);    // Accel BW 94Hz,
Delay 3ms / Gyro BW 98Hz, Delay 2.8ms, Fs 1KHz
    else if(DLPF_SEL == 3) Wire.write(0x03);    // Accel BW 44Hz,
Delay 4.9ms / Gyro BW 42Hz, Delay 4.8ms, Fs 1KHz
    else if(DLPF_SEL == 4) Wire.write(0x04);    // Accel BW 21Hz,
Delay 8.5ms / Gyro BW 20Hz, Delay 8.3ms, Fs 1KHz
    else if(DLPF_SEL == 5) Wire.write(0x05);    // Accel BW 10Hz,
Delay 13.8ms / Gyro BW 10Hz, Delay 13.4ms, Fs 1KHz
    else Wire.write(0x06);    // Accel BW 5Hz, Delay 19ms / Gyro BW
5Hz, Delay 18.6ms, Fs 1KHz
    Wire.endTransmission(true);
}

void Gravity_Range_Option(){

```

```

switch(AFS_SEL) { // Selecting Gravity unit value
  case 0:
    Grvt_unit = 16384;
    break;
  case 1:
    Grvt_unit = 8192;
    break;
  case 2:
    Grvt_unit = 4096;
    break;
  case 3:
    Grvt_unit = 3276.8;
    break;
}
}

void Calib_MPU6050() {
  for(int i = 0 ; i < 2000 ; i++) { // Summing Iteration for finding
    calibration value
    if(i % 200 == 0) { // Display progress every 200 cycles
      cnt++;
      if(cnt == 1) { // Characters to display first
        Serial.print("Calculating .");

        lcd.clear();
        lcd.setCursor(0,0);
        lcd.print("Calculating");
      }
    }
  }
}

```

```

        lcd.setCursor(0,1);
        lcd.print(".");
    }
    else { // Display progress by point
        Serial.print(".");
        lcd.print(".");
    }
}

ReadData_MPU6050(); // Read Accelerometer data

delay(10);

// Sum data
Cal_AcX += AcX;
Cal_AcY += AcY;
Cal_AcZ += AcZ;
}

// Average Data
Cal_AcX /= 2000;
Cal_AcY /= 2000;
Cal_AcZ /= 2000;

// Serial Print
Serial.println("");
Serial.println("End of Calculation");

```

```

Serial.print("Cal_AcX = "); Serial.print(Cal_AcX);
Serial.print(" | Cal_AcY = "); Serial.print(Cal_AcY);
Serial.print(" | Cal_AcZ = "); Serial.println(Cal_AcZ);

// LCD Display
lcd.clear();
lcd.setCursor(0,0);
lcd.print("CalibValue X|Y|Z");
lcd.setCursor(0,1);
lcd.print(String(Cal_AcX) + "|" + String(Cal_AcY) + "|" +
String(Cal_AcZ));
delay(2000);
}

void ReadData_MPU6050() {
  Wire.beginTransmission(MPU_ADDR);
  Wire.write(0x3B);      // starting with register 0x3B
  (ACCEL_XOUT_H)
  Wire.endTransmission(false);
  //Wire.requestFrom(MPU_ADDR,14,true); // request a total of 14
registers
  Wire.requestFrom(MPU_ADDR,6,true); // request a total of 14
registers
  AcX=Wire.read()<<8|Wire.read(); // 0x3B (ACCEL_XOUT_H) &
0x3C (ACCEL_XOUT_L)
  AcY=Wire.read()<<8|Wire.read(); // 0x3D (ACCEL_YOUT_H) &
0x3E (ACCEL_YOUT_L)

```

```

    AcZ=Wire.read()<<8|Wire.read(); // 0x3F (ACCEL_ZOUT_H) &
    0x40 (ACCEL_ZOUT_L)
}

```

```

void Calc_Grvt() {

```

```

    AcX = (AcX - Cal_AcX); // Calibrated Accelerometer value

```

```

    AcY = (AcY - Cal_AcY); // Calibrated Accelerometer value

```

```

    AcZ = (AcZ - Cal_AcZ); // Calibrated Accelerometer value

```

```

    GAcX = AcX / Grvt_unit; // Converting the Calibrated value to
    Gravity value

```

```

    GAcY = AcY / Grvt_unit; // Converting the Calibrated value to
    Gravity value

```

```

    GAcZ = AcZ / Grvt_unit; // Converting the Calibrated value to
    Gravity value

```

```

    //----- Calculating Min, Max & Peak to Peak of Gravity -----
    -----

```

```

    Min_GAcX = min(Min_GAcX, GAcX);

```

```

    Max_GAcX = max(Max_GAcX, GAcX);

```

```

    PtoP_GAcX = Max_GAcX - Min_GAcX;

```

```

    Min_GAcY = min(Min_GAcY, GAcY);

```

```

    Max_GAcY = max(Max_GAcY, GAcY);

```

```

    PtoP_GAcY = Max_GAcY - Min_GAcY;

```

```

Min_GAcZ = min(Min_GAcZ, GAcZ);
Max_GAcZ = max(Max_GAcZ, GAcZ);
PtoP_GAcZ = Max_GAcZ - Min_GAcZ;
}

void Display_Grvt() {
  //----- Serial print -----
  -----

  Serial.print("AcX= " + String(AcX));
  Serial.print(" |AcY= " + String(AcY));
  Serial.println(" |AcZ= " + String(AcZ));

  //----- LCD Display -----
  -----

  period = millis() - prev_time;

  if(period > 1000) {

    prev_time = millis();

    lcd.clear();
    lcd.setCursor(0,0);
    lcd.print("PeakToPeak X|Y|Z");
    lcd.setCursor(0,1);
    lcd.print(String(PtoP_GAcX) + "|" + String(PtoP_GAcY) + "|" +
String(PtoP_GAcZ));

```

```
Min_GAcX = 0;  
Max_GAcX = 0;  
Min_GAcY = 0;  
Max_GAcY = 0;  
Min_GAcZ = 0;  
Max_GAcZ = 0;  
}  
}
```